



Salima District Council

P/Bag 15

Salima

Tel: 01 262 819, Fax: 01 262 579

REQUEST FOR QUOTATIONS (FOR WORKS) LOT 1-CENTRAL CONSTITUENCY

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

To:

.....

..... Date: 23rd September 2024

The Procuring Entity named above invites you to submit your quotation for carrying out the works as described herein. Any resulting order shall be subject to the Government of Malawi General Conditions of Contract for Local Purchase Orders (available on request) except where modified by this Request for Quotations.

SECTION A: QUOTATION REQUIREMENTS

1) Description of Works and Location

BOREHOLE CONSTRUCTION AND SOLAR POWERED WATER SUPPLY RETICULATION- SALIMA CENTRAL.

- 2) Works are to commence by: **7 days** *.[days/weeks/months]* from the date of Contract.
- 3) Works to be completed by: **30 days/weeks/months]** from the date of order.
- 4) Quotations must be valid for **90** days from the date for receipt given below.
- 5) Quotations and supporting documents as specified in Section B must be clearly marked with the Procurement Number given above and must indicate acceptance of the stated terms and conditions.
- 6) Quotations must be received, in sealed envelopes no later than: **14:00** on **27 September 2024**.
- 7) Quotations must be returned to:
Procurement Unit
Salima District Council,
P/Bag 15, Salima.
Attn: District Procurement Officer
- 8) The attached Activity Schedule (for lump sum contracts) or Schedule of Rates and Prices (for contracts where payment is based on unit prices) *{delete as appropriate}* at Section C details the works to be performed. You are requested to quote by completing Sections B and C. Quotations shall cover all costs of labour, materials, equipment, overheads, profits and all associated costs for performing the works including all taxes and duties. The whole



Salima District Council

P/Bag 15

Salima

Tel: 01 262 819, Fax: 01 262 579

REQUEST FOR QUOTATIONS (FOR WORKS) **LOT 1-CENTRAL CONSTITUENCY**

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

cost of performing the works shall be included in the items stated and the cost of any incidental works shall be deemed to be included in the prices quoted.

- 9) Quotations that are responsive, qualified and technically compliant will be ranked according to price. Award of contract will be made to the lowest priced quotation by the issue of a Local Purchase Order.

Signed:Date:

Name..... Title/Position:.....

For and on behalf of the Procuring Entity

Salima District Council

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

Your quotation is to be returned on this Form by completing and returning Sections B and C including any other information and certification as stated within this RFQ.

SECTION B: QUOTATION SUBMISSION SHEET

- 1) Currency of Quotation: Malawi Kwacha
- 2) Works will commence withindays/weeks/months from date of Purchase Order.
- 3) Works will be completed bydays/weeks/months from date of Purchase Order
- 4) Validity period of this quotation isdays from the date for receipt of Quotations.
- 5) We attach the following documents:
 - (i) Section C of the Request for Quotations completed and signed;
 - (ii) A copy of our Trading Licence
 - (iii) NCIC certificate in civil works category above K50,000,000.00
 - (iv) A copy of Valid Annual Tax Clearance Certificate
 - (v) A Copy of Valid PPDA Certificate
 - (vi) A copy of Valid National water resources Authority (NWRA) Certificate
 - (vii) Relevant experience in construction of high yielding boreholes with evidence of successful works in past two years
 - (viii) Evidence of ownership of basic equipment i.e. Drilling Rig, Compressor, support trucks, geneset, Submersible pump, welding machines, survey machines.
- 6) We confirm that our quotation is subject to the terms and conditions stated in your Request for Quotations referenced above, and that any resulting contract will be subject to the Government of Malawi General Conditions of Contract for Local Purchase Orders.
- 7) We confirm that the prices quoted are fixed and firm for the duration of the validity period and will not be subject to revision or variation.

Quotation Authorisation:

Signed:..... Date:

Name: Title/Position:

Authorised for and on behalf of (Company name and seal):

.....

Registered Address:

.....

.....

.....

If any additional documentation is attached to your quotation, a signature and authorisation at Section B and Section C is still required as confirmation that the terms

Salima District Council

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

and conditions of this RFQ prevail over any attachments. If the Quotation is not authorised in Section B and Section C, the quotation may be rejected.

BILLS OF QUANTITIES FOR BOREHOLE CONSTRUCTION AND SOLAR POWERED WATER SUPPLY RETICULATION- SALIMA CENTRAL						
ITEM No.		STANDARDS/SPECIFICATIONS	UNIT	QUANTITY	UNIT COST	AMOUNT
1.0	<u>PRELIMINARIES AND GENERAL</u>	-				
1.1	Contractor's Mobilization and Demobilization		LS	1		
1.2	Provide for system pressure testing		LS	1		
1.3	Water abstraction Levy (Paid to National Water Resource Authority)		LS	1		
	SUB-TOTAL CARRIED TO BID SUMMARY					
2.0	<u>BOREHOLE CONSTRUCTION</u>	-				
2.1	Conduct a geophysical survey for the purpose of locating underground water. The survey report should indicate the rock formation and expected depth at which water can be struck		LS	1		
2.2	Drilling 140mm diameter borehole from 0-40m, minimum of 0.5l/s		m	40		
2.3	Drilling 140 mm diameter borehole from 40-51m, min 0.5l/s		m	11		

Salima District Council

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

2.4	Supply and Install uPVC plain class 10 pipes with to a finished diameter of 140mm	ISO 1452-2:2009, ISO/TR 4191:2014,ISO 4427-1:2009	m	39		
2.5	Supply and Install uPVC slotted pipes (screen) class 10 to a finished diameter of 140mm	ISO 1452-2:2009, ISO/TR 4191:2014,ISO 4427-1:2009	m	12		
2.6	Supply and install 140mm end caps	ISO 1452-2:2009, ISO/TR 4191:2014,ISO 4427-1:2009	No.	2		
2.7	Supply and place 2-4mm gravels, packed,	GS 1118:2016	ton	2		
2.8	Supply cement, mix and place grout seal above gravel,	Cement: BS 12	m	1		
2.9	Including any appropriate borehole development methodology and or combination of borehole development methods to develop water to clarity (e.g. air lifting, mechanical surging, high velocity jetting, backwashing, over-pumping		hours	4		
2.1	Conduct minimum 6-hour constant rate discharge test on hand pump (Constant yield pumping test)		hours	6		
2.11	Conduct up to 90% recovery test on hand pump boreholes		hours	4		
2.12	Carry out detailed water quality test (Physical, chemical and Biological tests by the Central Water Laboratory)		Ls	1		
	SUB-TOTAL CARRIED TO BID SUMMARY					

Salima District Council

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

3.0	<u>SOLAR POWER AND PUMP WORKS</u>	-				
3.1	Supply and install Grundfos Submersible Water Pump SQF 2.5- 2	ISO 95027330	No.	1		
3.2	Supply and install Grundfos Control Switch - Manual	ISO 50	No.	1		
3.3	Supply and install AFC or equivalent High Voltage Panel - minimum of 330 walts, open secuit voltage min 36V	IEC 61724-1, ISO 9060, ISO/IEC 17025	No.	6		
3.4	Supply and install HDPE and Nylon Rope fittings and accessories	ISO 1452-2:2009, ISO/TR 4191:2014,ISO 4427-1:2009	m	100		
3.5	Supply and install 4 core, 4 mm armoured cable by approved cable manufacturer		m	160		
3.6	Supply and install 4 core, 10 mm armoured cable by approved cable manufacturer		m	140		
3.7	Supply and install lightning arrestor		set	1		
3.8	Supply and install earth rod and accessories		set	1		
3.9	Supply and install Various Electrical Accessories		LS	1		
3.8	Fabricate, provide and install steel frame panel stands on approved site and firmly secured in Razor diamond fence		LS	1		
3.9	Supply submersible cable 4mm, 3 core		m	51		
	SUB-TOTAL CARRIED TO BID SUMMARY					

Salima District Council

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

4.0	<u>RETICULATION SYSTEM</u>	-				
4.1	Supply and install all in PPR Pipes, fittings and accessories	ISO 1452-2:2009, ISO/TR 4191:2014,ISO 4427-1:2009		1		
4.2	63 mm dia PPR Inlet pipe		m	12		
4.3	63mm dia. PPR Outlet pipe		m	12		
4.4	63mm dia. PPR Overflow and Washout pipe		m	12		
4.5	1" PPR pipe		m	80		
4.6	3/4" Cobra Taps (chrome or similar noncorrossive material)	ASTM A999/A999M-18,ISO 15875-3:2003, SANS 226:2009, SANS 1480:2005, BS 1010, BS/EN 1286	No.	16		
	Provide and install in HDPE Pipe, fittings and accessories	ISO 1452-2:2009, ISO/TR 4191:2014,ISO 4427-1:2009	LS	1		
4.7	50mm dia. HDPE Class 16		M	2500		
4.8	40mm dia.HDP Class 16		M	500		
4.9	32 mm dia. HDPE Class 16		M	400		
	<u>SUB-TOTAL CARRIED TO BID SUMMARY</u>					
5.0	<u>OVERHEAD STORAGE TANK AND MISCELLANEOUS</u>	-				
	-	-				
5.1	Overhead Tank stand minnum 7m above ground level and built in cement blockwork with re-inforced top support slab and access ladders as per drawing (min block strenght 5N/mm2)	Cement: BS 12, Concrete: BS 8500	No.	1		

Salima District Council

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

5.2	Provision of formwork (19mm block boards, timber and supporting poles)		M2	32		
5.3	Supply and install 10,000 litre plastic water storage tanks with accessories as shown on drawing. <i>(Preferably MacSteel Tanks) Or LOTTO</i>	SAA AS/NZS 4766-2006, ASTM D1998-21	No.	2		
5.3	Construct 2 Tap apron (Kiosks) with cement blocks 150x150x400 as per drawing complete with soakaway as shown on drawing (Must be finished with ash grey porcelain tiles on the face)	for 2 Bib tap kiosk length is 1500mm and include waste water management structures	No.	8		
5.4	Provide PVC and Stainless steel based water meters to each Kiosk (1 meter to measure production and 8 consumption)	ISO 4064-1:2014	No.	9		
5.5	Construct with cement block 150x150x400mm and plaster 700x500x500mm manhole with concrete reinforced lockable covers, to accommodate water flow meters		No.	9		
5.6	Construct 800mm x800mmx800mm reinforced concrete with Y12 bars structure to seal BH point with provision of 25mm airtation pipe	BH PVC must be min of 300mm above the ground (fix base plate at min 300mm above the ground)	N0	1		
5.7	Provide PPR or PVC 63mm gatevalve		N0	2		

Salima District Council

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

5.8	Provide PPR or PVC 50mm gatevalve to each main distribution line		N0	4		
5.9	Provide PPR or PVC 32mm gatevalve to each Kiosk		N0	8		
BID SUMMARIES						
SERIES						
No.						
	MEASURED CONTRACT WORKS					
1	PRELIMINARIES AND GENERAL					
2	BOREHOLE DRILLING					
3	SOLAR POWER AND PUMP WORKS					
4	RETICULATION SYSTEM					
5	OVERHEAD STORAGE TANK AND MISCELLANEOUS					
	SUB - TOTAL					
	<i>Sub Total For 1 BH Mechanisation</i>					
	Add 16.5% Value Added Tax (VAT)					
	Add 1% NCIC Levy					

Salima District Council

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

	Add 1% PPDA Levy					
	Bid Total Price For 1 BH Mechanisation					
	Add 5% Contingency					

Salima District Council

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

SECTION C: ACTIVITY SCHEDULE (TO BE PRICED BY BIDDER)

For Lump Sum Contracts

Item No.	Description of Activity	Price in Kwacha
	<i>BOREHOLE CONSTRUCTION AND SOLAR POWERED WATER SUPPLY RETICULATION- SALIMA CENTRAL</i>	
	Total Lump Sum Price	

The following attachments are appended to clarify the Description of Activity:

Authorised By:

Signature: _____

Name: _____

Position: _____

Date: _____

(DD/MM/YY)

Authorised for and on behalf of:

Company: _____

Salima District Council

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001

SECTIONC: SCHEDULE OF PERSONNEL AND THEIR QUALIFICATION (to be priced by Bidder)

Item No.	Personnel	Qualification	Experience

Authorised By:

Signature: _____ Name: _____

Position: _____ Date: _____

(DD/MM/YY)

Authorised for and on behalf of:

Company: _____

Salima District Council

Procurement Number: SADC/LOCAL GOVT/BOREHOLE/2024-2025/001